



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-150-17**

Valid from: 2024 02 12
until: 2026 02 12

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Plug for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3722-1863/23**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2024 01 08



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
OVE EN IEC 60309-1:2023-07-01
OVE EN IEC 60309-2:2023-07-01
IEC 60309-1:2021
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Plug for industrial purposes

Type designation:

Rating:

Trademark:

033
2P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

034
3P+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

035
3P+N+PE
IP 67 or IP 66/IP 67
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

0332 2P+PE IP 67 or IP 66/IP 67 see typelist	PCE / ELCEE / SIROX / METECEE
0342 3P+PE IP 67 or IP 66/IP 67 see typelist	PCE / ELCEE / SIROX / METECEE
0352 3P+N+PE IP 67 or IP 66/IP 67 see typelist	PCE / ELCEE / SIROX / METECEE
0331 2P+PE IP 44 see typelist	PCE / ELCEE / SIROX / METECEE
0341 3P+PE IP 44 see typelist	PCE / ELCEE / SIROX / METECEE
0351 3P+N+PE IP 44 see typelist	PCE / ELCEE / SIROX / METECEE
03321 2P+PE IP 44 see typelist	PCE / ELCEE / SIROX / METECEE
03421 3P+PE IP 44 see typelist	PCE / ELCEE / SIROX / METECEE
03521 3P+N+PE IP 44 see typelist	PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

0	3	5	2	1	-	6	cq	*	*
---	---	---	---	---	---	---	----	---	---

Contacts	
blank	nickel plated contacts
b	uncoated contacts

Colour	
blank	standard type
*	reserved for additional colours

Housing	
blank	Design 1
cq	Design 2

Clock position earthing contact	
1	1h
2	2h
3	3h
4	4h
5	5h
6	6h
7	7h
8	8h (not available in 4- and 5-poles)
9	9h
10	10h
11	11h
12	12h

Customer type	
-	Trademark PCE

Degree of protection	
blank	IP67 or IP66/IP67
1	IP44

Pilot contact	
blank	with pilot contact
2	without pilot contact

Poles	
3	3-poles
4	4-poles
5	5-poles

Rated current	
3	63A

Ground type	
0	Plug

OVE Certification


Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
033 0332 0331 03321	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	>50 – 250	DC	690
		4	100 – 130	50 and 60	690
		6	200 – 250	50 and 60	690
		7	480 – 500	50 and 60	690
		8	>250	DC	690
		9	380 – 415	50 and 60	690
		10	>50	>100 - 300	690
		12	Supply from an isolating transformer	50 and 60	690
034 0342 0341 03421	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	380 440	50 60	690
		4	100 – 130	50 and 60	690
		5	600 – 690	50 and 60	690
		6	380 – 415	50 and 60	690
		7	480 - 500	50 and 60	690
		9	200 – 250	50 and 60	690
		10	>50	>100 - 300	690
		11	440 – 460	60	690
		12	Supply from an isolating transformer	50 and 60	690
		035 0352 0351 03521	63	1	Other ratings
2	>50			>300 - 500	690
3	220/380 250/440			50 60	690
4	57/100 – 75/130			50 and 60	690
5	347/600 – 400/690			50 and 60	690
6	200/346 – 240/415			50 and 60	690
7	277/480 – 288/500			50 and 60	690
9	120/208 – 144/250			50 and 60	690
10	>50			>100 - 300	690
11	250/440 – 265/460			60	690
12	Supply from an isolating transformer			50 and 60	690

Accessories:

ts7632 •



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.